



| AIR / VACUUM PARTS LIST | | | | |
|-------------------------|----------|-------------|-----------------|------|
| PART NO. | DWG. NO. | DESCRIPTION | MATERIAL | QTY. |
| 1S | 60-1S | TOP | CAST IRON | 1 |
| 2 | 60-2H | FLANGE | CAST IRON | 1 |
| 3F | 60-3FH | BODY | CAST IRON | 1 |
| 4 | 60-4 | GASKET | ARMSTRONG | 1 |
| 5 | 60-5 | SEAT | BUNA-N RUBBER | 1 |
| 6S | 60-6 | FLOAT | STAINLESS STEEL | 1 |
| 11 | 80-11 | BOLT | STEEL | 8 |
| 11A | 606-11A | BOLT | STEEL | 2 |
| 12 | 60-12 | NUT | STEEL | 10 |
| 13 | 60-13 | BOLT | STEEL | 10 |
| 29A | PLG-.5 | PLUG | BRASS | 2 |
| 55 | 80-55 | LIFTING LUG | STEEL | 2 |

| INLET FLANGE DATA | |
|----------------------|-----------|
| FLANGE DIAMETER | 12.50 in. |
| FLANGE THICKNESS | 1.44 in. |
| BOLT CIRCLE DIAMETER | 10.62 in. |
| NUMBER OF BOLT HOLES | 12 |
| BOLT HOLE DIAMETER | 0.88 in. |

- NOTES:
1. INLET SIZE: 6" CLASS 250 FLANGE
 2. APPROXIMATE WEIGHT: 197 lbs.
 3. WHEN OPERATING PRESSURE IS BELOW 20 psig, REPLACE ITEM NO. 5 WITH SOFT SEALING MATERIAL DWG. NO. 60-5L.
 4. WHEN OPERATING PRESSURE IS ABOVE 150 psig, REPLACE ITEM NO. 5 WITH HARD SEALING MATERIAL DWG. NO. 60-5H.

| | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|-------------------------------------------------------------|--|
| 24 HOUR STATE BUSINESS SERVICE FOR 40 YEARS UNITED STATES PATENT OFFICE REGISTERED UNDER TRADEMARK ACT OF 1902 INTERNATIONAL TRADEMARK REGISTRATION NO. 100,000,000 REGISTERED UNDER TRADEMARK ACT OF 1902 INTERNATIONAL TRADEMARK REGISTRATION NO. 100,000,000 | | DATE: _____ TIME: _____ CHECKED BY: BUL DRAWN: DJF | |
| CRISPIN VALVES 6" CLASS 250 AIR / VACUUM VALVE | | DWG. NO. AL62 SHEET 1 OF 1 | |